











# Victaulic Vortex™ Fire Suppression System

SERIES 951 FLUID AND SERIES 951 ZONE CONTROL BOXES FOR USE WITH VICTAULIC  
VORTEX 1000 AND VICTAULIC VORTEX 1500 FIRE SUPPRESSION SYSTEMS

## ELECTRICAL SPECIFICATIONS ZONE BOX

**Operation Voltage:** 24VDC continuous power supply (23-27VDC), polarity sensitive

**Alarm Current:** 2 Amps

**Standby Current:** 22mA

**Supervisory Connections:** 500mA @30 VDC resistive load

## CONNECTIONS ZONE BOX

### DC Power – TB1

- 23-27 VDC Operation Voltage
- Supervised By System Fault Contact

### Release – TB2

- Nitrogen valve, 350 ohm
- Water valve, 350 ohm

### Supervisory – TB3

- System fault connection, 24V
- Provides the means to signal a system fault to another device
- Water isolation valve
- 500mA @ 30VDC resistive dry contacts

## INSTALLATION

Reference should always be made to the applicable I-VORTEX Victaulic Field Installation Handbook for the product you are installing. Handbooks are included with each shipment of Victaulic products for complete installation and assembly data.

## WARRANTY

Refer to the Warranty section of the current Price List or contact Victaulic for details.

## NOTE

This product shall be manufactured by Victaulic or to Victaulic specifications. All products to be installed in accordance with current Victaulic installation/assembly instructions. Victaulic reserves the right to change product specifications, designs and standard equipment without notice and without incurring obligations.

For complete contact information, visit [www.victaulic.com](http://www.victaulic.com)

70.08 6353 REV A UPDATED 11/2011

VICTAULIC IS A REGISTERED TRADEMARK OF VICTAULIC COMPANY. VICTAULIC VORTEX IS A TRADEMARK OF VICTAULIC COMPANY.  
© 2011 VICTAULIC COMPANY. ALL RIGHTS RESERVED.

70.08

