

Type Approval Certificate Extension

This is to certify that Certificate No. 13/60014 for the undernoted products is extended and renumbered as shown.

This certificate is issued to:

PRODUCER	Victaulic Company 4901 Kesslersville Road Easton, PA-18040 USA
PLACE OF PRODUCTION	Victaulic De Mexico,S.de R.L.de.C.V, Avendia Aerespecial No.12601, Parque Industrial Chihuahua Sur, Col. Tabalaopa, C.P. 31385 Mexico
DESCRIPTION	Compression Couplings- Press Type
TYPE	Vic-Press® system P507, P508, P560, P562, P563, P568, P571, P572, P573, P574, P575, P576, P577, P578, P579, P585
APPLICATION	The Vic-Press® type is approved for Class III systems in accordance with Table 12.2.7, Part 5, and Chapter 12 of the Ship Rules- Compression couplings- Press - Fire resistant type.
STANDARD	Rules and Regulations for Classification of Ships Rules and Regulations for Classification of Special Service Craft Rules and Regulations for Offshore Units
Certificate No.	13/60014(E1)
Issue Date	30 Aug 2018
Expiry Date	29 Aug 2023
Sheet	1 of 2



Gopal Nair

Lloyd's Register Quality Assurance, Inc.

Lloyd's Register Quality Assurance, Inc.
1330 Enclave Parkway, Suite 200, Houston, Texas 77077

Lloyd's Register Quality Assurance Inc.
Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

RATINGS

Size ½ "to 2" Sch.10S type 316 Stainless Steel
Seal HNBR and EDPM
MAWP 16 bar (232 psi)
Maximum Temp 98° C (HNBR), 121° C (EPDM)


LIMITATIONS:

- A) Suitability of any valves supplied with the system should be established as per Rule requirements.
B) Where threaded connections and end fittings are employed it will be further limited by Rule requirements.
C) The use of the Vic-Press® is not permitted in the following applications:
1. Starting and control air piping systems arranged in Machinery space of Category A.
 2. Dry pipe systems for all fire fighting/deluge/water spray.
 3. Inert gas piping systems arranged in machinery spaces of Category A, pump rooms and open decks.
 4. Piping systems of Class I and II
 5. Gaseous and liquid media which will obstruct the press fitting system or attack the material synthetic seals.
 6. Reuse of press type is not permitted.

"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register Quality Assurance, Inc. of any modification or changes to the equipment in order to obtain a valid certificate."

The Design Appraisal Document No. 13/60014(E1) and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Certificate No. 13/60014(E1)
Issue Date 30 Aug 2018
Expiry Date 29 Aug 2023
Sheet 2 of 2



Gopal Nair

Lloyd's Register Quality Assurance, Inc.

Lloyd's Register Quality Assurance, Inc.
1330 Enclave Parkway, Suite 200, Houston, Texas 77077

Lloyd's Register Quality Assurance Inc.
Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.