



Lloyd's
Register

Type Approval Certificate

This is to certify that the undernoted product has been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

This certificate is issued to:

PRODUCER	Victaulic Company
ADDRESS	4901 Kesslersville Road, Easton, Pennsylvania- 18040 USA
ALTERNATE PLACE OF PRODUCTION	Quality Castings 1200 North Main Street Orrville, Ohio 44667 USA
PRODUCT DESCRIPTION	Victaulic Style W07 AGS Rigid Coupling & W77 AGS Flexible Coupling
PRODUCT TYPE	Advanced Grooved System (AGS) mechanical pipe couplings Style W07 - AGS Rigid Coupling, Style W77 - AGS Flexible Coupling Sizes 14" - 24" (350mm - 600mm) Material: Ductile Iron conforming to ASTM A-536, Grade 65-45-12 Gasket - Material: Grade E (EPDM)
SIZES	14" to 24" (350 mm to 600 mm)
SPECIFIED STANDARD	Lloyd's Register Rules and Regulations for Classification of Offshore Units-2014 Lloyd's Register Rules and Regulations of Classification of Ships-2016 IACS UR P. 211
Certificate No.	16/60001
Issue Date	29 June 2016
Expiry Date	28 June 2021
Sheet	1 of 3

Gopal Nair
Lloyd's Register North America, Inc.

1330 Enclave Parkway, Suite 200, Houston, Texas 77077 USA
A member of Lloyd's Register Group Limited

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

RATING Rated Working Pressure: 232 psi (16 bar)
Temperature Range: Minus 30°F to 230°F (Minus 34 °C to 110 °C)
EPDM E Gasket


APPLICATION Marine and Offshore applications for the following services:

	Systems	Limitation
1	Fresh, Sea Water Cooling	For application to specific systems refer to Rules and Regulations for the Classification of Ships Part 5, Chapter 12 section 2.12 and table 12.2.7
2	Ballast	
3	Fire Mains, Water Spray and Sprinkler Applications	
4	Sanitary, Potable Water Systems	
5	Vents, Overflows	
6	Scrubber	

LIMITATIONS OR OTHER CONDITIONS

- a) The EPDM E gaskets have passed the fire tests in accordance with IACS UR P.2.11.
- b) The above fittings are to be installed in accordance with manufacturer's instructions to the satisfaction of the attending Surveyor.
- c) Material – Ductile Iron ASTM A 536 Grade 65-45-12.
- d) Couplings are not to be used in systems where pressure pulsation is expected.
- e) All fittings on the class I systems are to be grooved type

Certificate No. 16/60001
Issue Date 29 June 2016
Expiry Date 28 June 2021
Sheet 2 of 3



Gopal Nair
Lloyd's Register North America, Inc.

1330 Enclave Parkway , Suite 200, Houston, Texas 77077 USA
A member of Lloyd's Register Group Limited

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



"This Certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register North America, Inc. of any modification or changes to the equipment in order to obtain a valid certificate."

The attached Design Appraisal Document No. 16/60001 and its supplementary Type Approval Terms and Conditions form part of this Certificate

Certificate No.	16/60001
Issue Date	29 June 2016
Expiry Date	28 June 2021
Sheet	3 of 3

Gopal Nair
Lloyd's Register North America, Inc.

*1330 Enclave Parkway, Suite 200, Houston, Texas 77077 USA
A member of Lloyd's Register Group Limited*

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.